

CIVIC CENTER DEMOLITION BID

RFI 1 Addendum 2

June 18, 2026

- What fill materials shall be used and what recommended compaction percent?
Select Fill- Plasticity index between 8-18. 95% compaction.
- How deep do we need to go to remove footers? **Up to 5 feet.**
- Must we conduct a site visit in order to bid? **Yes. A site visit and walkthrough are mandatory for all bidders. Only bidders who have completed the required site visit and walkthrough will be eligible to submit a bid.**

*****NOTE: All addenda issued for this solicitation shall be considered part of the Bid Packet and shall be incorporated into and made a part of the Contract Documents. Bidders are responsible for acknowledging receipt of all addenda and for incorporating any modifications or requirements contained therein into their bid submissions.***